Distribution: Supervisor/Department Head
Employee and Labor Relations

Safety Survey

Grossmont-Cuyamaca Community College District

Grossmont ☐ Cuyamaca ☐

Campus Location:

Date:

Surveyor:

Contact Person:

Child Development Center

		Acceptable				If "No," Abatement		
		Yes	No	N/A	Details/Comments	Who	When	Completed
	Housekeeping							
a.	Are classroom decorations placed in a safe and acceptable manner? Curtains should be noncombustible or treated with a flame-retardant application; doors and the areas immediately around them should be kept free of decorations; artwork suspended from the ceiling should be of minimal volume so as to not create an additional fire spread hazard.							
b.	Are floors clear and free of trip/slip hazards, is obsolete material regularly removed to prevent excess accumulation, and is housekeeping adequate?							
c.	Are aquariums and terrariums anchored or secured to prevent falling?							
d.	Are file cabinets, freestanding cabinets, bookcases or other top-heavy furniture secured or anchored to prevent falling?							
	Personal Appliances							
e.	Are toasters and/or toaster ovens least 36 inches away from combustible materials?							
f.	Are microwaves or small refrigerators that are located above shoulder height secured to prevent falling?							

		Acceptable				If "No," Abatement		
		Yes	No	N/A	Details/Comments	Who	When	Completed
Electrical								
g.	Are electrical outlets above the level at which a child can reach it? If they are within reach, are they covered with a safety cover?							
h.	Is decorative lighting located away from combustible materials?							
i.	Is permanent wiring in use rather than extension cords?							
j.	If extension cords must be used on a temporary basis, are they out of the way and not spread across walkways?							
Playgrounds								
k.	Are repairs and maintenance performed in accordance with the specifications of the manufacturer?							
l.	Are playground supervisors trained in the basics of playground safety and safe supervisory techniques?							
m.	Is playground landscape and hardscape of an appropriate type and condition and well-maintained?							
n.	Are there jump ropes, cables, leashes, or similar items hung from or around playground equipment?							
o.	Is playground equipment of commercial quality and anchored in place?							
p.	Is the protective surfacing conditioned/raked/leveled to keep it full, clean and an even surface? Is the protective surface maintained at a sufficient depth to meet compliance standards?							
Child Development Center - Other								
q.	Are child development classrooms free of other apparent hazards or concerns?							
r.	Are playground areas otherwise free of other hazards?							
Comments								